

Exhibit ‘C’

The following sections, paragraphs, and sentences of Appendix AK of the *2021 International Residential Code* are hereby amended as follows: Standard type is text from the IRC Appendix K. Underlined type is text inserted. ~~Lined through type is deleted text from IRC Appendix K.~~

Section AK101 Airborne Sound

AK102.1 General

Airborne sound insulation for wall and floor-ceiling assemblies shall meet a sound transmission class (STC) rating of 45 (townhouses and two-family dwellings shall meet an STC rating of 58) where tested in accordance with ASTM E90 or a Normalized Noise Isolation Class (NNIC) rating of 42 (or 57 for attached dwelling units) where tested in accordance with ASTM E336. Penetrations or openings in construction assemblies for piping; electrical devices; recessed cabinets; bathtubs; soffits; or heating, ventilating or exhaust ducts shall be sealed, lined, insulated or otherwise treated to maintain the required ratings. Dwelling unit entrance doors, which share a common space, shall be tight fitting to the frame and sill.

[...]

Section AK103 Structural-Borne Sound

AK103.1 General

Floor/ceiling assemblies between dwelling units, or between a dwelling unit and a public or service area within a structure, shall have an impact insulation class (IIC) rating of not less than 45 (60 for townhouses and two-family dwellings) when tested in accordance with ASTM E492 or a Normalized Impact Sound Rating (NISR) of 42 (57 for attached dwelling units) where tested in accordance with ASTM E1007.

[...]
