

# Crowley Fire Department

## Fire Marshal's Office

201 E. Main Street  
Crowley, Texas 76036  
Phone (817) 297-2201 ex 5020  
[FireMarshal@ci.crowley.tx.us](mailto:FireMarshal@ci.crowley.tx.us)



### **Minimum Standards to request overhead sprinkler inspection**

The minimum compliance requirements for the installation and/or modification of automatic sprinkler suppression systems as prescribed by national codes & standards, state regulations and as adopted by local ordinance.

**Please Note: A minimum of (2) inspections are required.**

**1. Hydrostatic pressure test and a visual inspection of the piping prior to cover-up.**

**2. Final acceptance test.**

1. Be sure to include all compliance documents with your request ensuring they are legible and complete. If you are requesting final inspections for multiple buildings, a separate email package shall be required for each building, address, project, etc. requested. The Final Acceptance test shall not be scheduled until all required documents are on file with the Crowley Fire Marshal's Office.
2. Fully executed SF-041 "Contractor's Material & Test Certification"
3. Statement of Compliance letter signed & dated by the RME-G
4. As-Built Drawings
5. The inspection request form.
6. Final inspections of systems utilizing "Concealed Heads" shall be performed without the plates installed.
7. If you do not have access to email or experience electronic difficulties, you may hand deliver all documents referenced to: the City of Crowley Permit office located at 201 E. Main Street, Crowley Texas 76036.
8. Phone # 817-297-1638 ex 5020.
9. Please submit your request a minimum of 48 business hours in advance. All inspections are scheduled on a first-come, first-serve basis. All installations, modifications or alterations must be pre-tested prior to scheduling.
10. Fire Marshal's Office will then schedule your request via return email confirming the date and approximate time. A licensed person associated with the registered contracting company shall be present at all Final Acceptance Test with the AHJ.

If you have any questions or unusual circumstances please contact our office at (817)-297-1638 ex 5020

The following information shall assist with the minimum compliance requirements for the installation and modification of automatic sprinkler suppression systems as prescribed by national codes & standards, state regulations and as adopted by local ordinance.

**Texas Insurance Code Chapter 6003 (formerly Article 5.43-3) Fire Protection Sprinkler System Service and Installation and 28 TAC §§ 34.700 The Fire Sprinkler Rules - summer 2016**

- Sec. 6003.003. Effect on Local Regulation
- §34.707. Adopted Standards
- §34.711. Responsible Managing Employee (RME) License
- §34.716. Installation, Maintenance, and Service
- §34.717. Sprinkler System Plans
- §34.718. Installation Tags
- §34.720. Inspection, Test & Maintenance Service (ITM) Tag
- SF-041 - Contractor's Material and Test Certificate for Aboveground Piping
- SF-040 - Work Permitted by Type of License

**International Fire Code, 2015 Edition**

- Preface
  - Introduction
  - Development
  - Adoption
  - Maintenance
- Chapter 1 – Scope and Administration
- Chapter 5 – Fire Protection Water Supplies
- Chapter 9 – Fire Protection Systems
- Chapter 80 – Referenced Standards

**NFPA 13, 2019 Edition**

- Chapter 1 – Administration
- Chapter 23 – Plans & Calculations
- Chapter 24 – Water Supplies
- Chapter 25 – System Acceptance