


Underground Fire line

The Crowley Fire Department currently operates under the 2021 IFC with amendments.

Please review the Supporting documents for submittal requirements:

Underground Fire Service & Remote FDC Installations

Performing the inspections of underground fire service and remote FDC installations has become progressively more difficult over the years. Safety concerns are expressed that piping may become dislodged during the hydrostatic pressure test, so contractors are back filling natural soil to a degree the critical features for visual inspections of the piping installation are completely obstructed and cannot be verified for compliance.



Supporting Documents

Underground Inspection Procedure 487.75 KB

Statement of Compliance Letter Example 107.21 KB

Underground Fire Service Installation Diagram 839.74 KB

Inspection Request Form 285.46 KB

NFPA Guide for Underground Fire Service Installation 252 KB

SF 042 Underground 299.22 KB

SFMO Fact for Underground Installation 132.68 KB

Permit Application for Underground Fire lines. 227.87 KB

Crowley signage Requirements for the Fire Marshal 1.79 MB