

## Exhibit ‘F’

### Amendments to the 2021 International Mechanical Code

The following sections, paragraphs, and sentences of the *2021 International Mechanical Code* (IMC) are hereby amended as follows: Standard type is text from the IMC. Underlined type is text inserted. ~~Lined through type is deleted text from the IMC.~~

---

***Section 102.8; change to read as follows:***

**102.8 Referenced Codes and Standards.** The codes and standards referenced herein shall be those that are listed in Chapter 15 and such codes and standards shall be considered part of the requirements of this code to the prescribed extent of each such reference. Where differences occur between provisions of this code and the referenced standards, the provisions of this code shall apply. Whenever amendments have been adopted to the referenced codes and standards, each reference to said code and standard shall be considered to reference the adopted amendments. Any reference to NFPA 70 shall mean the National Electrical Code as adopted.

---

***Section 103 and 103.1; change to add name of department responsible for enforcement:***

**~~SECTION 103 CODE COMPLIANCE AGENCY~~ COMMUNITY DEVELOPMENT DEPARTMENT**

**103.1 Community Development Department.** The Community Development Department is the agency responsible for the implementation, administration and enforcement of the provisions of this code, and the official responsible for implementation, administration and enforcement of this code shall be known as the code official.

~~The [INSERT NAME OF DEPARTMENT] is hereby created and the official in charge thereof shall be known as the code official. The function of the agency shall be the implementation, administration and enforcement of the provisions of this code.~~

---

***Section 306.5; change to read as follows:***

**306.5 Equipment and Appliances on Roofs or Elevated Structures.** Where *equipment* requiring access or appliances are located on an elevated structure or the roof of a building such that personnel will have to climb higher than 16 feet (4877 mm) above grade to access, an interior or exterior means of access shall be provided. Exterior ladders providing roof access need not extend closer than 12 feet (2438 mm) to the finish grade or floor level below and shall extend to the *equipment* and appliances' level service space. Such access shall . . . {bulk of section to read the same} . . . on roofs having a slope greater than four units vertical in 12 units horizontal (33-percent slope). ... {remainder of text unchanged}.

---

***Section 306.5.1; change to read as follows:***

**306.5.1 Sloped Roofs.** Where appliances, *equipment*, fans or other components that require service are installed on a roof having a slope of three units vertical in 12 units horizontal (25-percent slope) or greater and having an edge more than 30 inches (762 mm) above grade at such edge, a catwalk at least 16 inches in width with substantial cleats spaced not more than 16 inches apart shall be provided from the roof access

to a level platform at the appliance. The level platform shall be provided on each side of the appliance to which access is required for service, repair or maintenance. The platform shall be not less than 30 inches (762 mm) in any dimension and shall be provided with guards. The guards shall extend not less than 42 inches (1067 mm) above the platform, shall be constructed so as to prevent the passage of a 21-inch-diameter (533 mm) sphere and shall comply with the loading requirements for guards specified in the *International Building Code*...{remainder of text unchanged}.

---

**Section 501.3; add an exception to read as follows:**

**501.3 Exhaust Discharge.** The air removed by every mechanical exhaust system shall be discharged outdoors at a point where it will not cause a public nuisance and not less than the distances specified in Section 501.3.1. The air shall be discharged to a location from which it cannot again be readily drawn in by a ventilating system. Air shall not be exhausted into an attic, crawl space, or be directed onto walkways.

**Exceptions:**

1. Whole-house ventilation-type attic fans shall be permitted to discharge into the attic space of dwelling units having private attics.
2. Commercial cooking recirculating systems.
3. Where installed in accordance with the manufacturer's instructions and where mechanical or natural ventilation is otherwise provided in accordance with Chapter 4, listed and labeled domestic ductless range hoods shall not be required to discharge to the outdoors.
4. Toilet room exhaust ducts may terminate in a warehouse or shop area when infiltration of outside air is present.

**END**